

ErP Product Fiche In accordance with EU1253/2014 & EU1254/2014



	L01233/2014 & L01234/201	•		
(a)	Supplier Name	Vectaire Ltd		
(b)	Model	MAXI		
		Cold	Average	
(c)	Specific Energy Consumption (KWh/(m².a))	-81.77	-43.05	-18.24
	SEC Class	A+	A+	Е
(d)	RVU or NRVU / Unidirectional or Bidirectional	RVL	J / Bidirect	ional
(e)	Type of drive installed	Variable Speed		
(f)	Type of heat recovery system	Recuperative		
(g)	Thermal efficiency of heat recovery	86%		
(h)	Maximum flow rate (m ³ /h)	533		
(i)	Electric power input at maximum flow rate (W)	174.6		
(j)	Sound power level (L _{WA})	52		
(k)	Reference flow rate (m ³ /s)	373		
(l)	Reference pressure difference (Pa)	50		
(m)	Specific Power Input (W/(m³/h))	0.20		
(n)	Control factor	0.65		
	Control typology	Local Demand Control		
(o)	Maximum internal leakage rate	< 5%		
(0)	Maximum external leakage rate	< 5%		
(p)	Mixing rate of non-ducted bidirectional ventilation units not	N1/A		
	intended to be equipped with one duct connection on either supply or extract air side	N/A		
	Position and description of visual filter warning for RVUs			
(q)	intended for use with filters, including text pointing out the	Refer to O&M manual		
	importance of regular filter changes for performance and energy			
	efficiency of the unit			
	For unidirectional ventilation systems, instructions to install	N/A		
(r)	regulated supply/exhaust grilles in the façade for natural air			
	supply/extraction			
(s)	Internet address for disassembly instructions	www.vectaire.co.uk		
(t)	For non-ducted units only: the airflow sensitivity to pressure variations at + 20Pa and – 20 Pa	N/A		
(u)	For non-ducted units only: the indoor/outdoor air tightness in	N/A		
(4)	m ³ /h		1 4/ / 1	
(v)	Annual Electricity Consumption per 100m ² (kWh/a)	Cold	Average	Warm
		686.38	149.38	104.38
(w)	Annual Heating Saved (kWh/a)	Cold	Average	Warm
		9019.49	4610.57	2084.84

